



January 20, 2011

ORENCO SYSTEMS INC
GOVERNMENT RELATIONS
ANGELA BOUNDS
814 AIRWAY AVE
SUTHERLIN OR 97479

Re: Description: SEWAGE TREATMENT APPARATUS, EFFLUENT FILTER
Manufacturer: ORENCO SYSTEMS INC
Product Name: EFFLUENT SCREENS
Model Number(s): NON-ADJUSTABLE MODELS: ES1540, ES1548, ES12510, ES1840, ES1848, ES1860, ES2040, ES2048, ES2060, ES2440, ES2448, ES2460 [All Non-Adjustable models have the option of a Float Bracket (FB) and/or Flow Inducer (FI)] [**>1/8 IN. FILTRATION**]

ADJUSTABLE MODELS: E15A, E18A, E20A, 20AFI [All Adjustable models have the option of a Float Bracket (FB) or Flow Inducer (FI)] [**>1/8 IN. FILTRATION**]
Product File No: 20110029

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of MAY 2016.**

This approval is contingent upon compliance with the following stipulation(s):

- Installation and servicing of this product must be in accordance with the manufacturer's instructions. A copy of the manufacturer's installation and servicing instructions must be given to the owner of the system.
- An access opening of sufficient size to allow removal of the filter must be provided over the outlet tee baffle of which this product is installed. This access opening must terminate at or above grade.
- Maintenance information must be given to the owner of the tank explaining that periodic cleaning of the filter will be necessary.
- This product must be installed in sewage treatment tanks approved by the Department of Commerce, Division of Safety and Buildings for use with this product.
- MAINTENANCE: Clean filter at inspection/pumping interval.

This approval supersedes the approval issued on 5/19/2006 & 9/14/2009 under product file number 20060201.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20060201.

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Products Review
Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456; E-mail: Jean.MacCubbin@WI.GOV